CIVIL XPERTS
ISO 9001:2008
CONSULTANTS & TESTING CENTER

174, Sri Ranga Complex
Amrutha Nagar Main Road
New Bank Colony, Konanakunte
Bangalore - 560 062.
Mobile : +91 97429 59595
Tele/Fax : 080-2632 2565
E-mail : civilexpertsltd@gmail.com
URL : www.civilexperts.in

NABL ACCREDITED AS PER ISO/IEC 17025:2005

Job No.: CECTC/BBMP/KRIDL/W.No.13/CUBE/2017-18 11.05.2017

TEST REPORT ON COMPRESSIVE STRENGTH OF CONCRETE CUBES

Client : **Asst. Executive Engineer,** Project Sub Division-1, Dasarahalli Zone, BBMP, Bangalore.

Agency : **Executive Engineer,** KRIDL, BBMP, Bangalore.

Name of the work : Providing fencing to Balance portion of Mallasandra Quarry Sy No.33 in Ward No.13 Mallasandra Project subdivision, Dasarahalli zone, BBMP, Bangalore.

Sample ID : Cement Concrete

Size of cubes : 150mmx150mmx150mm

Cross Sectional Area : 22500 mm^2

Technical Reference : IS: 516-1959 (Reaffirmed 2008)

Grade of Concrete : M_{20}

Compressive Strength as on : 28^{th} day

Sl.No.	Date of casting	Date of testing	Weight of cube (Kg)	Failure load (KN)	Compressive strength (N/mm^2)
1	13.04.2017	11.05.2017	8.276	482.5	21.44
2	13.04.2017	11.05.2017	8.326	495.8	22.04
3	13.04.2017	11.05.2017	8.397	501.7	22.30

Note:

1. The report shall not be reproduced, except in full, without the written approval of the laboratory.
2. The results indicated above are based on the tests carried out on the samples received in the laboratory.
3. Any Query regarding the report must be reported within 15 days from the date of testing.

Ravi. N.K. AE Project.

For Civil Experts Consultants

Authorised Signatory

Asst. Executive Engineer
Project Sub Division-I
Dasarahalli Zone,
Bangalore-57

CIVIL XPERTS
ISO 9001:2008
CONSULTANTS & TESTING CENTER

174, Sri Ranga Complex
Amrutha Nagar Main Road
New Bank Colony, Konanakunte
Bangalore - 560 062.
Mobile : +91 97429 59595
Tele/Fax : 080-2632 2565
E-mail : civilexpertsltd@gmail.com
URL : www.civilexperts.in

NABL ACCREDITED AS PER ISO/IEC 17025:2005

Job No.: CECTC/BBMP/KRIDL/W.No.13/CUBE/2017-18 12.05.2017

TEST REPORT ON COMPRESSIVE STRENGTH OF CONCRETE CUBES

Client : **Asst. Executive Engineer,** Project Sub Division-1, Dasarahalli Zone, BBMP, Bangalore.

Agency : **Executive Engineer,** KRIDL, BBMP, Bangalore.

Name of the work : Providing fencing to Balance portion of Mallasandra Quarry Sy No.33 in Ward No.13 Mallasandra Project subdivision, Dasarahalli zone, BBMP, Bangalore.

Sample ID : Cement Concrete

Size of cubes : 150mmx150mmx150mm

Cross Sectional Area : 22500 mm^2

Technical Reference : IS: 516-1959 (Reaffirmed 2008)

Grade of Concrete : M_{20}

Compressive Strength as on : 28^{th} day

Sl.No.	Date of casting	Date of testing	Weight of cube (Kg)	Failure load (KN)	Compressive strength (N/mm^2)
1	14.04.2017	12.05.2017	8.278	486.7	21.63
2	14.04.2017	12.05.2017	8.334	495.8	22.04
3	14.04.2017	12.05.2017	8.374	503.4	22.37

Note:

1. The report shall not be reproduced, except in full, without the written approval of the laboratory.
2. The results indicated above are based on the tests carried out on the samples received in the laboratory.
3. Any Query regarding the report must be reported within 15 days from the date of testing.

For Civil Experts Consultants

Ravi. N.L
AE Project

Authorised Signatory

Asst. Executive Engineer
Project Sub Division-I
Dasarahalli Zone
Bruhat Bengaluru Mahanagara Palike

CIVIL XPERTS
ISO 9001:2008
CONSULTANTS & TESTING CENTER

174, Sri Ranga Complex
Amrutha Nagar Main Road
New Bank Colony, Konanakunte
Bangalore - 560 062.
Mobile : +91 97429 59595
Tele/Fax : 080-2632 2565
E-mail : civilexpertsltd@gmail.com
URL : www.civilexperts.in

NABL ACCREDITED AS PER ISO/IEC 17025:2005

Job No.: CECTC/BBMP/KRIDL/W.No.13/CUBE/2017-18 12.05.2017

TEST REPORT ON COMPRESSIVE STRENGTH OF CONCRETE CUBES

Client : **Asst. Executive Engineer,** Project Sub Division-1, Dasarahalli Zone, BBMP, Bangalore.

Agency : **Executive Engineer,** KRIDL, BBMP, Bangalore.

Name of the work : Providing fencing to Balance portion of Mallasandra Quarry Sy No.33 in Ward No.13 Mallasandra Project subdivision, Dasarahalli zone, BBMP, Bangalore.

Sample ID : Cement Concrete

Size of cubes : 150mmx150mmx150mm

Cross Sectional Area : 22500 mm^2

Technical Reference : IS: 516-1959 (Reaffirmed 2008)

Grade of Concrete : M_{20}

Compressive Strength as on : 28^{th} day

Sl.No.	Date of casting	Date of testing	Weight of cube (Kg)	Failure load (KN)	Compressive strength (N/mm^2)
1	14.04.2017	12.05.2017	8.249	482.2	21.43
2	14.04.2017	12.05.2017	8.198	498.5	22.16
3	14.04.2017	12.05.2017	8.390	512.7	22.79

Note:

1. The report shall not be reproduced, except in full, without the written approval of the laboratory.
2. The results indicated above are based on the tests carried out on the samples received in the laboratory.
3. Any Query regarding the report must be reported within 30 days from the date of testing.

Rani.N.K. AE Project.

For Civil Experts Consultants

Authorised Signatory

Asst. Executive Engineer
Project Sub Division-I
Dasarahalli Zone,
Bruhat Bangalore Mahanagara Palike

CIVIL XPERTS
ISO 9001:2008
CONSULTANTS & TESTING CENTER

174, Sri Ranga Complex
Amrutha Nagar Main Road
New Bank Colony, Konanakunte
Bangalore - 560 062.
Mobile : +91 97429 59595
Tele/Fax : 080-2632 2565
E-mail : civilexpertsltd@gmail.com
URL : www.civilexperts.in

NABL ACCREDITED AS PER ISO/IEC 17025:2005

Job No.: CECTC/BBMP/KRIDL/W.No.13/CUBE/2017-18 12.05.2017

TEST REPORT ON COMPRESSIVE STRENGTH OF CONCRETE CUBES

Client : **Asst. Executive Engineer,** Project Sub Division-1, Dasarahalli Zone, BBMP, Bangalore.

Agency : **Executive Engineer,** KRIDL, BBMP, Bangalore.

Name of the work : Providing fencing to Balance portion of Mallasandra Quarry Sy No.33 in Ward No.13 Mallasandra Project subdivision, Dasarahalli zone, BBMP, Bangalore.

Sample ID : Cement Concrete

Size of cubes : 150mmx150mmx150mm

Cross Sectional Area : 22500 mm^2

Technical Reference : IS: 516-1959 (Reaffirmed 2008)

Grade of Concrete : M_{20}

Compressive Strength as on : 28^{th} day

Sl.No.	Date of casting	Date of testing	Weight of cube (Kg)	Failure load (KN)	Compressive strength (N/mm^2)
1	14.04.2017	12.05.2017	8.278	490.8	21.81
2	14.04.2017	12.05.2017	8.289	501.7	22.30
3	14.04.2017	12.05.2017	8.365	512.9	22.80

Note:

1. The report shall not be reproduced, except in full, without the written approval of the laboratory.
2. The results indicated above are based on the tests carried out on the samples received in the laboratory.
3. Any Query regarding the report must be reported within 30 days from the date of testing.

Javi.N.K. AE Project

For Civil Experts Consultants

Asst. Executive Engineer
Project Sub Division-I
Dasarahalli Zone,
Bruhat Bengaluru Mahanagara Palike

Authorised Signatory